

Montage Task Number	Action Taken Category – Class - Type	Department	Date Created	a. a description of any roadworks or excavation work performed by SEW, including the purpose and outcome of such works;	b. the location of the works.	c. the date those works were performed; and	d. any photographs depicting the works themselves or the location before and after the works were performed.
1297589/001	Plumbing Sewer - Sewer Drain - Inspection	SEW PriorityPlumbing	27/12/2024 10:42	Purpose: - Customer request for blocked plumbing. Outcome: - Plumber attended and found the blockage in South East Water's Property Connection Branch and cleared the blockage.	139 BAYVIEW ROAD, MCCRAE VIC 3938	27/12/2024	See folder 1297589 for Montage extracts
1297589/002	Sewer Network - Property Connection Branch - Unblock	SEW PriorityPlumbing	27/12/2024 12:26	Purpose: - Task created to capture blockage against South East Water's Asset. Outcome: - Blockage recorded.	139 BAYVIEW ROAD, MCCRAE VIC 3938	27/12/2024	
1304490/001	Sewer Network - Sewer Pipe - Digout	ServiceStream Sewer	23/01/2025 15:35	Purpose: - The scope of our works is: - Excavate a shaft to the depth of embedment of the sewer main (approximately 2.5m deep). Observe and measure the flow within the shaft. If required, install a trench stop and run a drainage pipe to the nearby Council stormwater pit located outside 1 Charlesworth Street. Outcome: - Observations were made with Mornington Peninsula Shire Council representatives, trench stop installed and excavation backfilled.	3 CHARLESWORTH STREET, MCCRAE VIC 3938	24/01/2025 – 28/01/2025	See folder 1304490 for Montage extracts
1304490/002	Sewer Network - General - Operational Support	SEW Sewer	24/01/2025 11:17	Purpose: - To record observations from the site inspection and capture photos. Outcomes: - Observations captured in Task Story.	3 CHARLESWORTH STREET, MCCRAE VIC 3938	24/01/2025 – 28/01/2025	
1304490/003	Sewer Network - Sewer Pipe - CCTV Inspection and Clean	ServiceStream Sewer	28/01/2025 15:15	Purposes: - Internally CCTV 3 sewer reticulation lines for structural and serviceability assessment. Outcome: - The CCTV was carried out on the lines with the lines assessed by South East Water.	3 CHARLESWORTH STREET, MCCRAE VIC 3938	29/01/2025	
1304490/004	Roadworks - Roadway - Reinstatement	Service Stream RI	31/01/2025 09:33	Purpose: - To reinstate the road and kerb and channel from the excavation works. Outcome: - 6 sqm of asphaltting was completed along with 2.1m of concrete kerb and channel.	3 CHARLESWORTH STREET, MCCRAE VIC 3938	12/2/2025 – Kerb and Channel reinstatement 18/2/2025 – Asphalt reinstatement	
1300775/001	Sewer Network - Sewer Pipe - Unblock	Downer Sewer	10/01/2025 13:19	Purpose: - To investigate and clear a sewer blockage in the reticulation sewer. Outcome: - Cleared blockage in the 150mm VC sewer line	36 COBURN AVENUE, MCCRAE VIC 3938	10/01/2025	See folder 1300775-001 for Montage extract
1338997/001	No Work Cancelled - No Work Cancelled - No Work Cancelled	ServiceStream Sewer	24/04/2025 12:25	Purpose: - To raise 3 maintenance structures to ground level for access. Outcome: - Task CANCELLED as per duplicate request.	38 COBURN AVENUE, MCCRAE VIC 3938	-	See folder 1338997 for Montage extracts
1338997/002	Sewer Network - Manhole - Cover alteration	ServiceStream Sewer	24/04/2025 12:31	Purpose: - To locate and raise 3 Maintenance Structures. Outcome: - 2 of the 3 Maintenance Structures raised to surface.	38 COBURN AVENUE, MCCRAE VIC 3938	2/5/2025	
1339645/001	Sewer Network - Manhole - Alteration	ServiceStream Sewer	28/04/2025 10:54	Purpose: - To raise Maintenance Structure to surface. Outcome: - Maintenance structure NEP39-509 was raised to surface 250mm.	26 COBURN AVENUE, MCCRAE VIC 3938	2/5/2025	See folder 1339645-001 for Montage extract
1340050/001	Sewer Network - Manhole - Cover Grease & Grind	ServiceStream Sewer	29/04/2025 15:21	Purpose: - To open Maintenance Structure NEP39-506. Outcome: - Access on obtained and a clean of the Maintenance Structure was carried out.	11 COBURN AVENUE, MCCRAE VIC 3938	30/4/2025	See folder 1340050-001 for Montage extract
1341250/001	Sewer Network - Manhole - Clean	Downer Sewer	4/05/2025 9:36	Purpose: - Maintenance Structure NEP39-506 to be cleaned. Outcome: - Maintenance structure was cleaned.	11 COBURN AVENUE, MCCRAE VIC 3938	6/5/2025	See folder 1341250-001 for Montage extract
1341738/001	Sewer Network - Manhole - Alteration	ServiceStream Sewer	6/05/2025 12:16	Purpose: - To raise Maintenance Structure NEP42-544 to surface. Outcome: - Maintenance structure NEP42-544 was raised to surface 350mm.	27 COBURN AVENUE, MCCRAE VIC 3938	22/5/2025	See folder 1341738-001 for Montage extract
1299529/001	Sewer Network - Sewer Pipe - Investigation	ServiceStream Sewer	5/01/2025 21:46	Purpose: - To investigate a possible sewer reticulation stoppage. Outcome: - Investigated the sewer with CCTV and no signs of sewer stoppage and/or sewer odour.	3 PENNY LANE, MCCRAE VIC 3938	5/1/2025	See folder 1299529 for Montage extract
1299529/002	Sewer Network - Manhole - Cover	ServiceStream Sewer	6/01/2025 14:36	Purpose: - To open Maintenance Structure NEP39-582. Outcome: - Replaced Maintenance Structure NEP39-582 cover in	14 HENRY COURT, MCCRAE 3938 (1	7/1/2025, 21/1/2025 –	

	alteration				CHARLESWORTH STREET, MCCRAE VIC 3938)		
1299529/003	Sewer Network - Sewer Pipe - CCTV Inspection and Clean	ServiceStream Sewer	24/01/2025 09:15	Purpose: - Internally CCTV 3 sewer reticulation lines for structural and serviceability assessment. Outcome: - The CCTV was carried out on the lines with the lines assessed by South East Water.	14 HENRY COURT, MCCRAE 3938 (1 CHARLESWORTH STREET, MCCRAE VIC 3938)	11/2/2025	
1299529/004	Roadworks - Roadway - Reinstatement	Service Stream RI	31/01/2025 09:45	Purpose: - To reinstate the road around Maintenance Structure after the cover replacement. Outcome: - 1 sqm of asphaltting was completed around the cover.	14 HENRY COURT, MCCRAE 3938 (1 CHARLESWORTH STREET, MCCRAE VIC 3938)	24/2/2025	
1303404/001	Sewer Network - Sewer Pipe - CCTV inspection	ServiceStream Sewer	20/01/2025 14:49	Purpose: - CCTV inspection of the sewer reticulation. Outcome: - The CCTV was carried out and assessed by South East Water.	16 PROSPECT HILL ROAD, MCCRAE VIC 3938	20/1/2025	See folder 1303404-001 for Montage extract
1337352/001	Sewer Network - Sewer Pipe - CCTV Inspection and Clean	ServiceStream Sewer	16/04/2025 15:45	Purposes: - Internally CCTV 39 sewer reticulation lines for structural and serviceability assessment. Outcome: - The CCTV was carried out on the lines with 37 lines assessed by South East Water.	27 COBURN AVENUE, MCCRAE VIC 3938 (Task includes assets in Prospect Hill Road, Coburn Avenue, Waller Place, Charlesworth Street)	16/4/2025, 22/4/2025 – 24/4/2025, 28/4/2025 – 2/5/2025, 5/5/2025 – 6/5/2025	See folder 1337352 for Montage extracts
1337352/002	Sewer Network - General - Operational Support	SEW Sewer	29/04/2025 08:59	Purpose: - To record times from the site inspection. Outcomes: - Task not used.	27 COBURN AVENUE, MCCRAE VIC 3938 (Task includes assets in Prospect Hill Road, Coburn Avenue, Waller Place, Charlesworth Street)	-	
1337352/003	Sewer Network - Sewer Pipe	ServiceStream Sewer	8/05/2025 15:24	Purposes: - Internally CCTV 2 sewer reticulation lines for structural and serviceability assessment. Outcome: - Not completed to date. Needs to be scheduled with property owner for access.	5 PROSPECT HILL ROAD, MCCRAE VIC 3938	-	
1337352/004	Sewer Network - Sewer Pipe	ServiceStream Sewer	22/05/2025 09:32	Purposes: - Please excavate and point repair 150mm VC sewer asset. Outcome: - Not completed to date. Needs to be scheduled.	7 HENRY COURT, MCCRAE 3938	-	
1337352/005	Sewer Network - Sewer Pipe	ServiceStream Sewer	5/06/2025 14:06	Purposes: - to patch the following sewers to prevent root ingress: 1052155978 - Patch at 10.8m U/S of NEP39-566; 1052156026 - Patch at 36m D/S of NEP42-515; 1052155962 - Patch at 37.7m D/S of NEP39-514; 1052155976 - Patch at 22.9m U/S of NEP39-577; 1052160456 - Patch at 1.0m D/S of NEP39-520; Outcome: - Not completed to date. Needs to be scheduled.	38 Coburn Ave 6-8 Prospect Hill Road 32 Coburn Ave 38 Coburn Ave Bayview Road	-	
1295094/009	Sewer Network - Sewer Pipe - Clean	ServiceStream Sewer	22/01/2025 15:22	Purpose: - Clean sewer reticulation main as signs of restricted flow. Outcome: - Cleaned line and removed tree roots from the sewer.	4 WALLER PLACE, MCCRAE VIC 3938	28/1/2025	See folder 1295094-009 for Montage extract
1341266/002	Sewer Network - General - Miscellaneous	ServiceStream Sewer	5/05/2025 8:27	Purpose: - To open Maintenance Structure NEP39-517. Outcome: - Grinded and greased the cover to sit flush when closed.	3 WALLER PLACE, MCCRAE VIC 3938	6/5/2025	See folder 1341266-002 for Montage extract
1107857/003	Sewer Network - Property Connection Branch - Reline	Downer Sewer	2/08/2023 11:09	Purpose: - Structurally reline the Property Connection Branch. Outcome: -cctv inspect and record pre clean, clean and prep drain for relining, Record post clean cctv and install 1800mm PCB liner in PVC.	6 VIEW POINT ROAD, MCCRAE VIC 3938	31/3/2025	See folder 1107857-003 for Montage extract