
Leak Report



2 Grandview Court McCrae Victoria 3938 Australia



CREATED

① 09/04/2025, 1:33:08 pm

by Stuart Haggett

LOCATION

○ -38.351298, 144.943309

PROJECT

South East Water

| Leak Address | 2 Grandview Court McCrae Victoria 3938 Australia |
|---|--|
| Zone | South East Water ► Cook St Tank Zone |
| Leak Asset Type | Mains |
| Flow Rate (L/min) | 7 |
| Has the leak been called in by DS Technician? | No |
| Leak Visible | Yes |



Comments

Possible leak on main, between driveway & sleeper wall.

Ground soft , wet & boggy, couldn't probe onto main, unknown location

Distant noise on hydrant

Leak Possibly on T Junction of 100upvc & 63pe.

May need to excavate/vacuum to locate main & chase water to leak

Sewer runs Parralel to main

Photo

