
# Leak Report



## 77 Flinders Street McCrae Victoria 3938 Australia



#### **CREATED**

- ① 15/05/2025, 9:58:31 am
- by Stuart Haggett

### **LOCATION**

○ -38.357178, 144.931191

#### **PROJECT**

Downer 🗅

	McCrae Victoria 3938 Australia
Zone	South East Water ► Reactive Leaks
Leak Asset Type	No Leaks Found
Has the leak been called in by DS Technician?	No
Job Ref	1343726/001
Leak Visible	No
Comments	Re-attended job at the request of Downer. Resounded meter & surroundsdead quiet  Gas line appears to be in line with water meterpotentially picking up noise from gas line if the customer has something running at night?  Another option would be to replace the meter in case the current meter installed is faulty.

**Photo** 





