Leak Report



93 Flinders Street McCrae Victoria 3938 Australia



CREATED

- ① 06/06/2025, 12:16:13 pm
- by Stuart Haggett

LOCATION

PROJECT

Service Stream

Leak Address	93 Flinders Street McCrae Victoria 3938 Australia
Zone	South East Water ► Reactive Leaks
Leak Asset Type	Toilet Cistern
Flow Rate (L/min)	8
Has the leak been called in by DS Technician?	No
Job Ref	LD023
Leak Visible	No



Comments

Arrived onsite. Builder onsite. Found meter turned off. Turned meter on & it started spinning over. Sounded 3x garden taps in front yard, all with distant faint noise.

Meanwhile Builder used toilet & noticed cistern continuously flowing, he fixed cistern & flow stopped, resounded meter & noise stopped & usage stopped.

Cistern was stuck open

MSR-29112

Photo

