

## Message

**From:** Swain, Charles [Charles.Swain@sew.com.au]  
**Sent:** 16/01/2025 1:17:38 PM  
**To:** Ramamurthy, Prerna [Prerna.Ramamurthy@sew.com.au]  
**CC:** Lloyd, Tim [Tim.Lloyd@sew.com.au]  
**Subject:** Summary of WQ results in McCrae  
**Attachments:** ALS WQ Results 311224.pdf; ALS WQ Results 090125.pdf; ALS WQ Results 070125.pdf

**Importance:** High  
**Flag:** Follow up

Hi Prerna,

See summary table below and ALS reports of the water samples collected and tested for 3 standard indicator parameters. My assessment of these results is that none of them reflect the typical measured parameter concentrations of the average throughout our potable water network (Avg. taken from 2024 WQ annual report). The closest was the sample taken in the stormwater drain in front of 6 View Point rd on 6 Jan but a follow up sample on 8 Jan was enough evidence to conclude that the water is highly unlikely to be potable water.

| ALS Water Sample No. | Water Sample Location                                  | Sample Date | EC - Electrical Conductivity (uS/cm) | Fluoride (Mg/L) | Chloride (Mg/L) |
|----------------------|--|-------------|--------------------------------------|-----------------|-----------------|
|                      | <i>SEW water network avg.</i>                          | -           | 83                                   | 0.77            | 9               |
| 10665285             | Pothole at the cnr of Waller Place and Charlesworth St | 24/12/2024  | 670                                  | 0.29            | 120             |
| 10665284             | Pothole at the cnr of Waller Place and Charlesworth St | 30/12/2024  | 640                                  | 0.27            | 120             |
| 10687819             | Pothole at the cnr of Waller Place and Charlesworth St | 6/01/2025   | 570                                  | 0.14            | 110             |
| 10665283             | Stormwater drain in front of 6 View Point Rd           | 30/12/2024  | 160                                  | 0.8             | 29              |
| 10697292             | Stormwater drain in front of 6 View Point Rd           | 8/01/2025   | 570                                  | 0.13            | 82              |
| 10687818             | Water from Landslide at the rear of 3 Penny Lane       | 6/01/2025   | 1600                                 | 0.15            | 330             |
| 106878120            | Pothole at the cnr of Coburn Rd and Charlesworth St    | 6/01/2025   | 750                                  | 0.3             | 140             |

Any Questions please let me know.

Cheers,

**Charles Swain**  
Water Maintenance Manager



WatersEdge 101 Wells Street  
Frankston VIC 3199

T +613 9552 3494

M PI



South East Water proudly acknowledges the Traditional Owners of the land on which we work and live, and pay respect to their Elders past, present and emerging. We acknowledge their songlines, cultural lore and continuing connection to the land and water. We recognise and value the rich cultural heritage and ongoing contributions of Aboriginal people and communities to our society in Victoria.