

Task Number: 1281290/001

Address: 43 BAYVIEW ROAD, MCCRAE VIC 3938

Creation Date: 25/10/2024 09:34

Request Type: Water Network - Service Pipe - Repair of leak

Priority: 7

Initial Comments: Customer called to advse small leak on service pipe going into the meter access ok no dogs

Action Taken: Water Network - Stop Tap - Repair of leak

Failure Details: 1 Water Stop Tap 32mm to 50mm - Leaking - Seal Failure

People onsite: Daniel Patterson

Job Comments: [Exall,Kirsty] [25/10/2024 09:34] [AWARDED]

Property Number:02E//00422/28

[Dowe,Ashleigh] [25/10/2024 09:45] [ALLOCATED]

CHECKED

[FT] [SSf0213] [25/10/2024 13:54] [ON SITE]

leak on 20mm stuffing box at st tightened and operated no leaks assembly exposed in 600mm trench