

Task Number: 1295097/001

Address: 34 COBURN AVENUE, MCCRAE VIC 3938

Creation Date: 16/12/2024 13:50

Request Type: Water Network - Water Main - Repair of leak in nature strip

Priority:5

Initial Comments: sss adved water is leaking in the nature strip slow trickle case

Action Taken: Water Network - Water Main - Inspection

Failure Details: 0 Not Our Asset - Not Our Asset - Not Our Asset

People onsite: Daniel Patterson

Job Comments: [Exall,Kirsty] [16/12/2024 13:50] [AWARDED]

Property Number:02E//00435/31

[Exall,Kirsty] [16/12/2024 13:51] [AWARDED]

case 085154456

[Ludewig,Ralph] [16/12/2024 13:53] [AWARDED]

Checked

[Ludewig,Ralph] [16/12/2024 13:59] [AWARDED]

poss duplicate of 1295094 listed as 4 waller place

[FT] [SSf0213] [17/12/2024 07:05] [ON SITE]

on site sounded all services in area and valves gained access to building site at no 34 no noise on short side service no storm water pipes connected of property slopping property and storm water running down to street raining on site tested at 398