

Task Number: 1298016/001

Address: 32 COBURN AVENUE, MCCRAE VIC 3938

Creation Date: Water Network - Water Main - Repair of leak in nature strip

Request Type: 29/12/2024 16:23

Priority: 5

Initial Comments: water main leakng in the ns, not alot of water

Action Taken: Water Network - Water Main - Inspection

Failure Details: 0 Not Applicable - Not Applicable - Not Applicable

People onsite: Ross Bartholomuesz

Job Comments: Irrelevant & Sensitive [29/12/2024 16:23] [AWARDED]

Property Number:02E//00435/28

[Scallion,Bradley] [29/12/2024 17:18] [UNAWARDED]

checked, works being done by service stream in mccrae, changing to them as I believe they wil llikely be linked.

[Scallion,Bradley] [29/12/2024 17:20] [AWARDED]

1295094/003 are works being done on waller place, notes state that there is more water in the stream than usual, possibly due to leak?

[FT] [LLf0129] [30/12/2024 08:16] [ON SITE]

Arrived on site to find water pushing up from roadway opposite number 3 Charlesworth St tested water & reading was high 670 walked up hill sounded services & valves no noises walked up Waller Place & can hear water gushing in stormwater drain then

[FT] [LLf0129] [30/12/2024 08:25] [ON SITE]

Irrelevant & Sensitive [29/12/2024 16:23] [AWARDED]

Property Number:02E//00435/28

[Scallion,Bradley] [29/12/2024 17:18] [UNAWARDED]

checked, works being done by service stream in mccrae, changing to them as I believe they wil llikely be linked.

[Scallion,Bradley] [29/12/2024 17:20] [AWARDED]

1295094/003 are works being done on waller place, notes state that there is more water in the stream than usual, possibly due to leak?

[Bartholomeusz,Ross] [30/12/2024 08:16] [ON SITE]

Arrived on site to find water pushing up from roadway opposite number 3 Charlesworth St tested water & reading was high 670 walked up hill sounded services & valves no noises walked up Waller Place & can hear water gushing in stormwater drain then SEW Jason Marsh on site we lifted stormwater lid & saw water like a burst flowing down drain lowered bucket with rope got sample & reading was 160 possible burst up hill on 300mm MSCL near Bayview RD or under freeway & getting into stormwater drain sounded valve ID 362971 & it was screaming SEW leak detection & operations are chasing leak will be informed of where leak is

[Shaikh,Anna] [30/12/2024 10:16] [OFF SITE]

Irrelevant & Sensitive

- reporting water seeping up from outside 32 coburn ave, lifting up the concrete and creating spongy areas

[FT] [SSf0010] [30/12/2024 12:57] [OFF SITE]

Leak has been located on job no-1295094/006