

Task Number: 1299529/001

Address: 3 PENNY LANE, MCCRAE VIC 3938

Creation Date: 5/01/2025 21:46

Request Type: Sewer Network - Sewer Pipe - Unblock

Priority: 1

Initial Comments: possible retic stoppage SS crew on site and has advised -430662 retic stoppage in upstream line-ec pen 651 testing please check manhole also .SES on site road has collapsed in 2 places and landslide to property

Action Taken: Sewer Network - Sewer Pipe - Investigation

Failure Details: 0 Not Applicable - Not Applicable - Not Applicable

People onsite: Brendan Pullen

Job Comments: [Murphy,Marilyn] [5/1/2025 21:46] [AWARDED]

Property Number:02E//00464/1

[Murphy,Marilyn] [5/1/2025 21:47] [AWARDED]

adv Wally

[Murphy,Marilyn] [5/1/2025 21:49] [AWARDED]

Wally organising Brendan to attend also

[FT] [SSf0196] [5/1/2025 23:47] [ON SITE SERVICE OK]

onsite, spoken with SES and Water crew, advised about issue up street, have checked MH NEP39-516 with ater leaking above and CCTV up with push rod, 15m and all clear, check u/s mh and this is clear, no smell or signs of sewer, spoken with resident who advised this leak has been going on since november, water crews have already attened, on Sewer section our assets are all ok. ahve left for water crew .